



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146BQ0134

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	LOXEAL S.r.l. Via G. Marconato, 2, I-20811 Cesano Maderno (MI)
Distributor <i>Vertreiber</i>	LOXEAL S.r.l. Via G. Marconato, 2, I-20811 Cesano Maderno (MI)
Product Category <i>Produktart</i>	Greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product description <i>Produktbezeichnung</i>	Anaerobic jointing compound, not permitted for the gas-installation according to DVGW-TRGI 2018
Model <i>Modell</i>	Loxeal 83-50
Test reports <i>Prüfberichte</i>	Laboratory control test: 21-00295-KP05- from 09.01.2025 (EBI) Type testing: 20-00095 from 12.05.2020 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 01.03.2030 / 24-0624-GNV
Ablaufdatum / Aktenzeichen

21.03.2025 Cat A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Loxal 83-50	Class: H	for dimensions > DN 10 up to DN 50

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

Suitable for metallic joints with coarse threads

Not permitted for the gas-installation according to DVGW-TRGI 2018